

# REPORT OF FIRE SPRINKLER INSPECTION

Owner/Occupant: \_\_\_\_\_ Date \_\_\_\_\_

Address: \_\_\_\_\_ INSPECTION

Phone: \_\_\_\_\_ Alarm Co.: \_\_\_\_\_ Phone: \_\_\_\_\_ REINSPECTION

The purpose of an automatic sprinkler system is to protect life and property. Serious fires seldom occur in properties completely protected with properly maintained automatic sprinkler systems. The responsibility for properly maintaining the fire protection system belongs to the owner (or the occupant). To properly maintain the system it shall be tested according to the National Fire Protection Association (NFPA 25), Standard for the Inspection, Testing and Maintenance of Water-Based Fire Protection Systems. Attention must be given not only to the system itself, but also to other features that may affect the proper and satisfactory control of fire by the sprinklers.

- |                                                                                                                                                                                                                                                                                                                                                                                              |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <p><b>1. TYPE OF SYSTEM</b><br/>                 Wet _____ Dry _____ Pre-Action _____<br/>                 Deluge _____ Anti-Freeze _____</p> <p><b>2. FIRE DEPARTMENT CONNECTION</b><br/>                 Condition _____<br/>                 Location _____</p> <p><b>3. SPRINKLER RISERS</b><br/>                 and size _____<br/>                 proper signs and marking _____</p> | <p><b>4. ALARMS</b><br/>                 Supervised _____<br/>                 Local _____</p> <p><b>5. CONTROL VALVES</b><br/>                 Size _____ Type _____<br/>                 Secured _____ Condition _____</p> <p><b>6. SPRINKLER HEADS ON HAND</b><br/>                 Number _____ Wrench _____</p> <p><b>7. BACKFLOW PREVENTION DEVICE</b><br/>                 Size _____<br/><br/>                 type: Double Check Valve _____<br/>                       Reduced Pressure Zone _____<br/><br/>                 Annual Certification: YES _____ NO _____</p> |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

### WATER FLOW TESTS

2" MAIN DRAIN TEST:      NO FIRE PUMP \_\_\_\_\_  
                                       FIRE PUMP OFF \_\_\_\_\_

- A. Record the static pressure on the pressure gauge on the system side of the check valve.
- B. Open the 2" main drain wide open and record the residual pressure.
- C. Close the 2" main drain tight and record the restored static pressure.

RISER#	1	2	3	4	5	6	7	8	9	10
STATIC PRESSURE										
RESIDUAL PRESSURE										
RESTORED STATIC PRESSURE										
1" INSPECTORS TEST										
LOCAL BELL TIME										
CENTRAL STATION/REMOTE STATION										

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Recommendations: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_